arison of Results

llowing tables of comparison show the differences between ETAP Results and those ed in the textbook example. Please note that the percentage difference for all branch flows s voltages is less than 1%.

COMPARISON BETWEEN ETAP AND REFERENCE FOR LOAD FLOW										
REFERENCE		ETAP								
		ANR			NR			FD		
%Mag.	Ang.	%Mag.	Ang.	%Diff Mag.	%Mag.	Ang.	%Diff Mag.	% Mag.	Ang.	%Diff Mag.
105	0	105	0	**0.00**	105	0	**0.00**	105	0	**0.00**
110	-3.34	110	-3.3	**0.00**	110	-3.3	**0.00**	110	-3.3	**0.00**
					100.08	-12.8	**0.00**	100.08	-12.8	**0.00**
					92.97	-9.8	**-0.01**	92.97	-9.8	**-0.01**
					91.98	-12.3	**0.00**			

P/Operation Technology, Inc. and may not be modified, copied,
d formats without the written authorization of ETAP/Operation
tion Technology, Inc. All Rights Reserved.